



NOTES:

1. INSTALL SIGNS AT ALL POINTS OF PUBLIC ACCESS (GATES, DRIVEWAYS, ETC.) AND AT 300 FEET INTERVALS (MINIMUM) ALONG PROJECT FENCELINE OR BORDER. IF EFFLUENT IS STORED IN PONDS, PROVIDE SIGNAGE AT PONDS.
2. SIGNS SHALL BE BILINGUAL, IN ENGLISH AND SPANISH.
3. PROVIDE METAL SIGN WITH WHITE LETTERS ON PURPLE BACKGROUND.
4. MOUNT SIGN ON FENCE OR METAL POST.
5. REFERENCE NDEP WTS-1A FOR ALTERNATE SIGNS THAT ARE ACCEPTABLE.

STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION		DRAWING No.	
	EFFLUENT WARNING SIGN	S-502	
		APPROVED BY: JE	DATE: 1/2020